ift-Nachweis

Classification Report

Number	19-003540-PR02 (NW-A01-02-en-01)
Owner	FEAL d.o.o. Trnska cesta 146 88220 Siroki Brijeg Bosnia and Herzegovina
Product	Tilt and turn window
Designation	System: Termo 65 Shipping name: Single tilt-turn window (opening inside)
Details	Manufacturer FEAL d.o.o., - Siroki Brijeg; Material Aluminium system with thermal break; Type of opening Tilt and turn; Opening direction DIN right, inward opening; Overall dimensions (W x H) 1230 mm x 1480 mm
Special features	Test sequence.

Result

Air permeability according to EN 12207:2016-12

Class: 4

Resistance to wind load according to EN 12210:2016-03

Class: C4/B4

Watertightness according to EN 12208:1999-11

Class: E900

ift Rosenheim
14.10.2019

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing

Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions (e.g. DIN EN)

Test report: 19-003540-PR02 PB-A01-02-en-01

Representation

Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check

www.ift-rosenheim.de/ift-geprueft
ID: 47C-4C0E4

Ve-PB1-4902-en/ (01.03.2019)